




DELHI JAL BOARD
(GOVT. OF N.C.T. DELHI)
QUALITY CONTROL LABORATORY,
WATER TREATMENT PLANT NANGLOI , DELHI-110041



Water Samples collected from "Delhi International School" Sector - 23, Dwarka, New Delhi -110077 Vide
Challan No. 110 Dt-25.07.2024.

**THE TEST REPORT IS
FOR THIS PARTICULAR
WATER SAMPLE ONLY**

S1: DJB Supply at above site

S2: Drinking Point with (RO) at above site.

Drinking Water with (RO) at above site.						
S. No.	Particulars	Units	Limit		S1	S2
			Acceptable	Permissible		
PHYSICAL EXAMINATION						
1.	Date of collection	-----	--	--	30.07.24	30.07.24
2.	Date of Analysis	-----	--	--	01.08.24	01.08.24
3.	Colour	CU	5.0	15	Clear	Clear
4.	Odour	-----	No. Objectionable		No Obj.	No Obj.
5.	Turbidity	N.T.U.	1.0	5.0	1.4	1.1
6.	PH value	-----	6.5	8.5	7.8	7.2
7.	Electrical Conductivity	µmho/cm	--	--	750.6	187
8.	Total dissolved solids	mg/l	500	2000	487.9	121.5
CHEMICAL EXAMINATION						
9.	Phenolphthalein Alkalinity	mg/l	--	--	NIL	Nil
10.	Total Alkalinity	mg/l	200	600	85	24
11.	Total Hardness	mg/l	200	600	168	30
12.	Calcium Hardness	mg/l	--	--	112	10
13.	Magnesium Hardness	mg/l	--	--	56	20
14.	Calcium as Ca	mg/l	75	200	44.8	4.0
15.	Magnesium as Mg	mg/l	30	100	13.44	4.8
16.	Ammonia as N	mg/l	0.5	N.R.	NIL	NIL
17.	Nitrite as N	mg/l	---	---	NIL	NIL
18.	Nitrate as NO ₃	mg/l	45	N.R.	-	-
19.	Sulphate	mg/l	200	400	48	10
20.	Chloride	mg/l	250	1000	128	50
21.	Dissolved Iron	mg/l	1	N.R.	0.10	0.02
22.	Fluoride	mg/l	1	1.5	0.34	0.08
23.	Cyanide	mg/l	0.05	N.R.	ND	ND
24.	Residual Chlorine	mg/l	0.20(min)	1.0	0.30	NIL
BACTERIOLOGICAL EXAMINATION						
25.	Coli-form per 100 ml at 37°C	MPN	0		0	0
REMARKS: As per tested parameters Sample -S1 & S2 are						

REMARKS: As per tested parameters Sample -S1 & S2 can be used for drinking purpose.


Schandy
ACWA 01/08/24
Asstt. Chief Water Analyst
DELHI JAL BOARD
Govt. of N.C.T. Delhi
Quality Control Laboratory
Water Warden W

Boh
BACT. Manager
Delhi International School
Sector-23, Dwarka
New Delhi-110077

San
A/CHEMIST
(Principal)
DELHI INTERNATIONAL SCHOOL
Recognised Sr. Sec. School & Affiliated to CBSE
Sector-23, Dwarka, New Delhi-110077



MUNICIPAL CORPORATION OF DELHI
OFFICE OF DEPUTY HEALTH OFFICER
NAJAFGARH ZONE



No: DHO/NGZ/MCD/2024/D-613

Dated 24/07/2024

1. Name of the School: - DELHI INTERNATIONAL SCHOOL
2. SCHOOL ADDRESS - SEC-23, DWARKA, NEW DELHI-110077.
3. NO. OF SHIFT ONE TIMING 08:00 AM TO 02:00 PM
4. NO. OF STUDENTS: BOYS - 958 GIRLS - 598 TOTAL = 1556
5. NO. OF STAFFS: MALE- 11 FEMALE - 65 TOTAL = 76


Details of Accommodations present in School

1. Floor Space in the Classroom Sufficient/insufficient **SUFFICIENT**
2. The Classrooms are Well Lighted/ill lighted **WELL LIGHTED**
3. The Classrooms are Well Ventilated/ill ventilated **WELL VENTILATED**
4. The Classrooms are kept / Not kept Neat & Clean: **NEAT AND CLEAN**
5. The Building requires/does not required Whitewash etc. **NOT REQUIRED**
6. The Drinking Water is Wholesome/Not wholesome **WHOLESOME**
7. The Latrine arrangement is Sanitary/Insanitary **SANITARY FROM HEALTH POINT OF VIEW.**


No. of toilets seats for student

1. One latrine-cum-urinal is required for 25 female student, so total is **SUFFICIENT**
2. One latrine for 40 male student is required so total is **SUFFICIENT**
3. Separate Toilet arrangement for staff present: Yes/No **YES SEPARATE EXISTS FOR STAFF.**
4. The Overall facilities: Good/ Adequate/Inadequate **GOOD FROM HEALTH POINT OF VIEW.**

If building Department or any other govt. agency takes actions against u/a construction or any dispute, then the Health Certificate will be stand cancelled /revoked without any further intimation in this regard


Deputy Health Officer
Najafgarh Zone
Municipal Corporation Of Delhi
Health Deptt., Najafgarh Zone

(Remarks: This Certificate is valid for one year from the date of issue and this has no bearing on any unauthorized construction)


Manager
Delhi International School
Sector-23, Dwarka
New Delhi-110077


(Principal)
DELHI INTERNATIONAL SCHOOL
Recognised Sr. Sec. School & Affiliated to CBSE
Sector-23, Dwarka, New Delhi-110077